

DS Duct Sleeve - Intumescent Duct Sleeve

New Product at R&M Fixings and Supports Ltd

R&M's range of DS duct sleeves are intended for use where a ventilation duct passes through a fire rated wall. The sleeve maintains the integrity of the fire rated wall which would otherwise be lost.

In the event of a fire, the advanced DS Duct Sleeve will expand with the heat, crushing the duct and closing off the hole to the fire for at least 2 hours.

The Ventilation duct sleeves are available to fit all common sizes of plastic ventilation duct and are suitable for retro fitting with access only required from one side.

- **2 Hour fire rating to BS 476**
- **Suitable for use through a wide range of fire partition walls**
- **Offers excellent acoustic insulation**
- **Maintains the thermal insulation of the duct through the penetration**
- **Maintains vapour seal of existing insulation**
- **Cost effective: one sleeve can replace two collars, easily cut to size to minimize wastage, no mastic is required, reducing on site time**
- **Sleeve can be easily fitted only requiring access from one side**
- **Allows the thermal movement of the duct**
- **Simple to install without special tools or skills**

Fire Tests - DS Duct Sleeves have undergone and passed testing in line with BS476 Part 22:1987 at Chiltern International Fire

Availability - DS Duct sleeves are currently available in the following nominal sizes:

Code	Item	Width [mm]	Height [mm]	Length [mm]	Fire Rating
AFDS110	Duct Sleeve	110	54	180	120 mins
AFDS150	Duct Sleeve	150	70	180	120 mins
AFDS204	Duct Sleeve	204	60	180	120 mins
AFDS215	Duct Sleeve	215	25	180	120 mins
AFDS22090	Duct Sleeve	220	90	180	60 mins
AFDS225	Duct Sleeve	225	25	180	120 mins
AFDS235	Duct Sleeve	234	29	180	120 mins
AFDS300	Duct Sleeve	300	25	180	120 mins
AFDS308	Duct Sleeve	308	29	180	120 mins

R&M Fixings & Supports Ltd

Unit 6, Central Trading Estate, Marine Parade, Southampton, SO14 5JP

Tel: **023 8038 6800** Fax: **023 8038 6808** Email: fixings@rm-electrical.com www.rm-electrical.com